



中国认可
国际互认
检测
TESTING
CNASL1145

国家强制性产品认证 试验报告

☐新申请 ☒变更 ☐监督 ☐复审 ☐其他

申请编号: A2024CCC0304-4440621

(任务编号)

产品名称: 交流接触器

型 号: NXC□-06□, NXC□-06□/N, NXC□-09□,
NXC□-09□/N, NXC□-12□,
NXC□-12□/N, NXC□-16□,
NXC□-16□/N, NXC□-18□,
NXC□-18□/N, NXC□-22□,
NXC□-22□/N


检测机构: 上海电器设备检测所有限公司



样品名称：交流接触器 型 号：NXC□-06□， NXC□-06□/N,NXC□-09□， NXC□-09□/N,NXC□-12□， NXC□-12□/N,NXC□-16□， NXC□-16□/N,NXC□-18□， NXC□-18□/N,NXC□-22□， NXC□-22□/N 商 标：正泰/CHINT 样品数量：8 台 样品来源：工厂送样 收样日期：2024-05-31 完成日期：2024-06-17	委托人：浙江正泰电器股份有限公司 委托人地址：浙江省乐清市北白象镇正泰 工业园区正泰路 1 号 生产者：浙江正泰电器股份有限公司 生产者地址：浙江省乐清市北白象镇正泰 工业园区正泰路 1 号 生产企业：浙江正泰电器股份有限公司 生产企业地址：浙江省乐清市北白象镇正 泰智能电器工业园区长江路 2 号
--	---

试验结论：依据 GB/T 14048.4-2020 检验合格

本申请认证单元所覆盖的产品型号规格及相关情况说明：
见附页 1。

主检：王宇 日期：2024.06.19	
审核：冯林 日期：2024.06.19	
签发：龙晓丽 日期：2024.06.19	

备注：		
变更项目	变更前	变更后
变更内容	见附页2	见附页2
原证书编号	2024010304630554	
原测试报告编号	00901-V2023CQC107502-1127136	
原检测单位	上海电器设备检测所有限公司	

附页 1:

NXC□-06□,NXC□-06□/N,NXC□-09□,NXC□-09□/N,NXC□-12□,
NXC□-12□/N,NXC□-16□,NXC□-16□/N,NXC□-18□,NXC□-18□/N,
NXC□-22□,NXC□-22□/N

Uimp:8kV;

Ui:690V;

Ith:

NXC-06, NXCF-06, NXC-06/N, NXCF-06/N, NXC-06XM, NXCF-06XM,
NXC-06XM/N, NXCF-06XM/N, NXC-09, NXCF-09, NXC-09/N, NXCF-09/N,
NXC-09XM, NXCF-09XM, NXC-09XM/N, NXCF-09XM/N:20A;
NXC-12, NXCF-12, NXC-12/N, NXCF-12/N, NXC-12XM, NXCF-12XM,
NXC-12XM/N, NXCF-12XM/N, NXC-16, NXCF-16, NXC-16/N, NXCF-16/N,
NXC-16XM, NXCF-16XM, NXC-16XM/N, NXCF-16XM/N:25A;
NXC-18, NXCF-18, NXC-18/N, NXCF-18/N, NXC-18XM, NXCF-18XM,
NXC-18XM/N, NXCF-18XM/N, NXC-22, NXCF-22, NXC-22/N, NXCF-22/N,
NXC-22XM, NXCF-22XM, NXC-22XM/N, NXCF-22XM/N:32A;

Ue: AC220V/230V,AC380V/400V,AC660V/690V;

NXC-06, NXCF-06, NXC-06/N, NXCF-06/N, NXC-06XM, NXCF-06XM,
NXC-06XM/N, NXCF-06XM/N:

AC-1:Ue/Ie:AC220V/230V/20A,AC380V/400V/20A,AC660V/690V/20A;

AC-3:Ue/Ie:AC220V/230V/6A,AC380V/400V/6A,AC660V/690V/3.8A;

AC-4:Ue/Ie:AC220V/230V/6A,AC380V/400V/6A,AC660V/690V/3.8A;

NXC-09, NXCF-09, NXC-09/N, NXCF-09/N, NXC-09XM, NXCF-09XM,
NXC-09XM/N, NXCF-09XM/N:

AC-1:Ue/Ie:AC220V/230V/20A,AC380V/400V/20A,AC660V/690V/20A;

AC-3:Ue/Ie:AC220V/230V/9A,AC380V/400V/9A,AC660V/690V/6.6A;

AC-4:Ue/Ie:AC220V/230V/9A,AC380V/400V/9A,AC660V/690V/6.6A;

NXC-12, NXCF-12, NXC-12/N, NXCF-12/N, NXC-12XM, NXCF-12XM,
NXC-12XM/N, NXCF-12XM/N:

AC-1:Ue/Ie:AC220V/230V/25A,AC380V/400V/25A,AC660V/690V/25A;

AC-3:Ue/Ie:AC220V/230V/12A,AC380V/400V/12A,AC660V/690V/8.9A;

AC-4:Ue/Ie:AC220V/230V/12A,AC380V/400V/12A,AC660V/690V/8.9A;

NXC-16, NXCF-16, NXC-16/N, NXCF-16/N, NXC-16XM, NXCF-16XM,
NXC-16XM/N, NXCF-16XM/N:

AC-1:Ue/Ie:AC220V/230V/25A,AC380V/400V/25A,AC660V/690V/25A;

AC-3:Ue/Ie:AC220V/230V/16A,AC380V/400V/16A,AC660V/690V/8.9A;

AC-4:Ue/Ie:AC220V/230V/16A,AC380V/400V/12A,AC660V/690V/8.9A;

NXC-18, NXCF-18, NXC-18/N, NXCF-18/N, NXC-18XM, NXCF-18XM,
NXC-18XM/N, NXCF-18XM/N:

AC-1:Ue/Ie:AC220V/230V/32A,AC380V/400V/32A,AC660V/690V/32A;

AC-3:Ue/Ie:AC220V/230V/18A,AC380V/400V/18A,AC660V/690V/12A;

AC-4:Ue/Ie:A AC220V/230V/18A,AC380V/400V/18A,AC660V/690V/12A;

附页 1: (续)

NXC-22, NXCF-22, NXC-22/N, NXCF-22/N, NXC-22XM, NXCF-22XM, NXC-22XM/N, NXCF-22XM/N:

AC-1:Ue/Ie:AC220V/230V/32A,AC380V/400V/32A,AC660V/690V/32A;

AC-3:Ue/Ie:AC220V/230V/22A,AC380V/400V/22A,AC660V/690V/14A;

AC-4:Ue/Ie:AC220V/230V/22A,AC380V/400V/18A,AC660V/690V/12A;

Us:AC24V,AC36V,AC42V,AC48V,AC110V,AC120V,AC127V,AC220V,AC230V,

AC240V,AC277V,AC380V,AC400V,AC415V,AC440V,AC460V,AC480V,

AC525V,AC600V,AC660V,50Hz,50/60Hz,60Hz;

极数:3P;

外壳防护等级:

NXC-06, NXCF-06, NXC-06/N, NXCF-06/N, NXC-09, NXCF-09, NXC-09/N, NXCF-09/N, NXC-12, NXCF-12, NXC-12/N, NXCF-12/N, NXC-16, NXCF-16, NXC-16/N, NXCF-16/N, NXC-18, NXCF-18, NXC-18/N, NXCF-18/N, NXC-22, NXCF-22, NXC-22/N, NXCF-22/N:IP20 (仅适用于正前侧);

NXC-06XM, NXCF-06XM, NXC-06XM/N, NXCF-06XM/N, NXC-09XM,

NXCF-09XM, NXC-09XM/N, NXCF-09XM/N, NXC-12XM, NXCF-12XM,

NXC-12XM/N, NXCF-12XM/N, NXC-16XM, NXCF-16XM, NXC-16XM/N,

NXCF-16XM/N, NXC-18XM, NXCF-18XM, NXC-18XM/N, NXCF-18XM/N,

NXC-22XM, NXCF-22XM, NXC-22XM/N, NXCF-22XM/N: IP50 (接线端子除外)

配用的辅助触头: (本体)

1NO1NC;

Ith:10A;

AC-15:Ue/Ie:AC220V/230V/2.7A,AC380V/400V/1.5A;

DC-13:Ue/Ie:DC220V/0.3A

检验项目汇总表

[illegible]