



中国国家强制性产品认证证书

证书编号：2024010304651298

认证委托人名称及地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产者名称及地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称及地址

上海诺雅克电气有限公司
上海市松江区思贤路3857号

产品名称和系列、型号、规格

软起动器

NJR2-355D, NJR2-400D, NJR2-450D, NJR2-500D,
TR120-355D, TR120-400D, TR120-450D, TR120-500D 参数详见附页

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求，特发此证。

发证日期：2024年07月02日 有效期至：2029年07月01日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2024010304651298

证书附页: 第 1 页 共 1 页

NJR2-355D,NJR2-400D,NJR2-450D,NJR2-500D,
TR120-355D,TR120-400D,TR120-450D,TR120-500D U_i :660V; U_{imp} :6kV;
 U_e :AC380V; I_{th} :NJR2-355D,TR120-355D:634A; NJR2-400D,TR120-400D:720A;
NJR2-450D,TR120-450D:810A; NJR2-500D,TR120-500D:900A;
 I_e :NJR2-355D,TR120-355D:634A; NJR2-400D,TR120-400D:720A;
NJR2-450D,TR120-450D:810A; NJR2-500D,TR120-500D:900A;
 P_e :355kW(NJR2-355D/TR120-355D),400kW(NJR2-400D/TR120-400D) ,
450kW(NJR2-450D/TR120-450D),500kW(NJR2-500D/TR120-500D); 使用类
别:AC-53b; 极数:3P; 外壳防护等级(IP):IP20;

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010304651298

NAME AND ADDRESS OF THE APPLICANT

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province,
P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province,
P.R.China

NAME AND LOCATION OF THE FACTORY

NOARK Electrics (Shanghai) Co., Ltd.

No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

Soft Starter

NJR2-355D,NJR2-400D,NJR2-450D,NJR2-500D,
TR120-355D,TR120-400D,TR120-450D,TR120-500D See attached page for details

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.02,2024

Valid until: Jul.01,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010304651298

Appendix : Page 1 of 1

NJR2-355D,NJR2-400D,NJR2-450D,NJR2-500D,
TR120-355D,TR120-400D,TR120-450D,TR120-500D U_i :660V; U_{imp} :6kV;
 U_e :AC380V; I_{th} :NJR2-355D,TR120-355D:634A; NJR2-400D,TR120-400D:720A;
NJR2-450D,TR120-450D:810A; NJR2-500D,TR120-500D:900A;
 I_e :NJR2-355D,TR120-355D:634A; NJR2-400D,TR120-400D:720A;
NJR2-450D,TR120-450D:810A; NJR2-500D,TR120-500D:900A;
 P_e :355kW(NJR2-355D/TR120-355D),400kW(NJR2-400D/TR120-400D) ,
450kW(NJR2-450D/TR120-450D),500kW(NJR2-500D/TR120-500D); Utilization
Category:AC-53b; Poles:3P; levels of protection(IP):IP20;

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.