



# 产品认证证书

证书编号: CQC2005010307169394

申请人名称及地址

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

制造商名称及地址

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称及地址

上海诺雅克电气有限公司(V012845)  
上海市松江区思贤路3857号

产品名称和系列、规格、型号

万能式断路器

NA8-3200;Uimp:12kV;Ui:1000V;Ue: AC400V;In:1600A, 2000A, 2500A, 3200A;过电流脱扣器类型:电子式;lcs=100kA;lcu=100kA;lcw=85kA/1s;使用类别: B; 极数: 3P, 4P; 适用于隔离;配用的辅助触头:3NO3NC, 5NO5NC; lth=6A;Ue/le: AC-15 AC230V/2A, AC400V/2A;Ue/le: DC-13 DC110V/2A, DC220V/0.3A

产品标准和技术要求

GB/T14048.2-2008

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年06月01日 有效期至: 2024年11月07日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任:

陆梅



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0283591



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2005010307169394

**NAME AND ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

NOARK Electrics (Shanghai) Co., Ltd. (V012845)

No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Air Circuit Breaker

NA8-3200;Uimp:12kV;Ui:1000V;Ue: AC400V;In:1600A, 2000A, 2500A, 3200A;Over-current ReleaseType: ETU;lcs=100kA;lcu=100kA;lcw=85kA/1s;Utilitization Category: B; Poles: 3P, 4P; Suitable for isolation;Attached Auxiliary Contacts:3NO3NC, 5NO5NC; lth=6A;Ue/le: AC-15 AC230V/2A, AC400V/2A;Ue/le: DC-13 DC110V/2A, DC220V/0.3A

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.2-2008

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Jun.01,2020

Valid until: Nov.07,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

**President:**

陆梅

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0283591