



中国国家强制性产品认证证书

证书编号：2024010304651716

认证委托人名称及地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产者名称及地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称及地址

上海诺雅克电气有限公司
上海市松江区思贤路3857号

产品名称和系列、型号、规格

软起动器

NJRM5-□/ZX□, TR151-□/ZX□; 详见附页

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求, 特发此证。

发证日期: 2024年07月03日 有效期至: 2029年07月02日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2024010304651716

证书附页：第 1 页 共 2 页

NJRM5-□/ZX□, TR151-□/ZX□

Uimp: 8kV;

Ui: 详见下表;

Ith: 详见下表;

Ue: 详见下表;

Ie: 详见下表;

Pe: 详见下表;

使用类别: AC-53a;

极数: 3P;

防护等级: IP20;

产品型号		Ue	Ui	Ie	Ith	Pe	
NJRM5-74/ZX2	TR151-74/ZX2	AC220V	660V	70A	70A	18.5kW	
NJRM5-90/ZX2	TR151-90/ZX2			84A	84A	22kW	
NJRM5-110/ZX2	TR151-110/ZX2			103A	103A	30kW	
NJRM5-74/ZX3	TR151-74/ZX3	AC380V		70A	70A	37kW	
NJRM5-90/ZX3	TR151-90/ZX3			84A	84A	45kW	
NJRM5-110/ZX3	TR151-110/ZX3			103A	103A	55kW	
NJRM5-74/ZX4	TR151-74/ZX4	AC460V	1000V	70A	70A	45kW	
NJRM5-90/ZX4	TR151-90/ZX4			84A	84A	55kW	
NJRM5-110/ZX4	TR151-110/ZX4			103A	103A	75kW	
NJRM5-74/ZX5	TR151-74/ZX5	AC575V		70A	70A	55kW	
NJRM5-90/ZX5	TR151-90/ZX5			84A	84A	75kW	
NJRM5-110/ZX5	TR151-110/ZX5			103A	103A	75kW	
NJRM5-74/ZX6	TR151-74/ZX6	AC690V		70A	70A	75kW	
NJRM5-90/ZX6	TR151-90/ZX6			84A	84A	90kW	
NJRM5-110/ZX6	TR151-110/ZX6			103A	103A	110kW	

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号：2024010304651716

证书附页：第 2 页 共 2 页

型号解释：

N JR M 5- □ / □ □

辅助代号 2：主回路电压等级，2 表 AC220V 等级；3 表示 AC380V 等级，4 表示 AC460V 等级；5 表示 AC575V 等级；6 表示 AC690V 等级。

辅助代号 1：工作方式，ZX 表示在线式软起动器。

规格代号：软起动器额定机型电流（单位：A）

设计序号：5

专供代号：行业 OEM

类别代号：交流软起动器

企业特征代号：N

T R 151- □ / □ □

辅助代号 2：主回路电压等级，2 表 AC220V 等级；3 表示 AC380V 等级，4 表示 AC460V 等级；5 表示 AC575V 等级；6 表示 AC690V 等级。

辅助代号 1：工作方式，ZX 表示在线式软起动器

规格代号：软起动器额定机型电流（单位：A）

设计序号：151

类别代号：交流软起动器

企业特征代号：T

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010304651716

NAME AND ADDRESS OF THE APPLICANT

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province,
P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province,
P.R.China

NAME AND LOCATION OF THE FACTORY

NOARK Electrics (Shanghai) Co., Ltd.

No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

Soft Starter

NJRM5-□/ZX□, TR151-□/ZX□

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.03,2024

Valid until: Jul.02,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304651716

Appendix : Page 1 of 1

NJRM5-□/ZX□, TR151-□/ZX□

Uimp: 8kV;

Ui: See the following table;

Ith: See the following table;

Ue: See the following table;

Ie: See the following table;

Pe: See the following table;

Utilization Category: AC-53a;

Poles: 3P;

IP20;

产品型号		Ue	Ui	Ie	Ith	Pe	
NJRM5-74/ZX2	TR151-74/ZX2	AC220V	660V	70A	70A	18.5kW	
NJRM5-90/ZX2	TR151-90/ZX2			84A	84A	22kW	
NJRM5-110/ZX2	TR151-110/ZX2			103A	103A	30kW	
NJRM5-74/ZX3	TR151-74/ZX3	AC380V		70A	70A	37kW	
NJRM5-90/ZX3	TR151-90/ZX3			84A	84A	45kW	
NJRM5-110/ZX3	TR151-110/ZX3			103A	103A	55kW	
NJRM5-74/ZX4	TR151-74/ZX4	AC460V	1000V	70A	70A	45kW	
NJRM5-90/ZX4	TR151-90/ZX4			84A	84A	55kW	
NJRM5-110/ZX4	TR151-110/ZX4			103A	103A	75kW	
NJRM5-74/ZX5	TR151-74/ZX5	AC575V		70A	70A	55kW	
NJRM5-90/ZX5	TR151-90/ZX5			84A	84A	75kW	
NJRM5-110/ZX5	TR151-110/ZX5			103A	103A	75kW	
NJRM5-74/ZX6	TR151-74/ZX6	AC690V		70A	70A	75kW	
NJRM5-90/ZX6	TR151-90/ZX6			84A	84A	90kW	
NJRM5-110/ZX6	TR151-110/ZX6			103A	103A	110kW	

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.