



# 产品认证证书

证书编号: CQC2014010307696150

**申请人名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**制造商名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**生产企业名称及地址**

上海诺雅克电气有限公司(V012845)  
上海市松江区思贤路3857号

**产品名称和系列、规格、型号**

万能式断路器  
NA8-4000H; 详情见附件

**产品标准和技术要求**

GB/T14048.2-2008

**认证模式**

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年06月01日      有效期至: 2024年05月22日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: 陆楠



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0290256



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2014010307696150

**NAME AND ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electric Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province

**NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang CHINT Electric Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province

**NAME AND ADDRESS OF THE FACTORY**

NOARK Electric (Shanghai) Co., Ltd. (V012845)  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Air circuit-breaker  
NA8-4000H; See the appendix

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.2-2008

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection  
This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

**Valid from:** Jun.01,2020

**Valid until:** May.22,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0290256



# 产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2014010307696150

纸号: 290256

NA8-4000H

额定冲击耐受电压 ( $U_{imp}$ ): 12kV;

额定绝缘电压 ( $U_i$ ): 1000V

额定工作电压 ( $U_e$ ): AC380/400/415V, AC690V

额定电流 ( $I_n$ ): 1000A, 1250A, 1600A, 2000A, 2500A, 2900A, 3200A, 3600A, 4000A

过电流脱扣器类型: 电子式

额定运行短路分断能力 ( $I_{cs}$ ): AC380/400/415V:  $I_{cs}=100kA$ ; AC690V:  $I_{cs}=85kA$

额定极限短路分断能力 ( $I_{cu}$ ): AC380/400/415V:  $I_{cu}=100kA$ ; AC690V:  $I_{cu}=85kA$

额定短时耐受电流 ( $I_{cw}$ ): AC380/400/415V:  $I_{cw}=100kA/1s$ ; AC690V:  $I_{cw}=85kA/1s$

AC380/400/415V:  $I_{cw}=75kA/3s$ ; AC690V:  $I_{cw}=75kA/3s$

使用类别: B

极数: 3P, 4P

适用于隔离

适用频率: 50/60Hz

配用的辅助触头 (4NO4NC, 6NO6NC):

$I_{th}$ : 6A

AC-15:  $U_e/I_e$ : AC230V/1.3A, AC400V/415V/0.75A

DC-13:  $U_e/I_e$ : DC110V/0.55A, DC220V/0.27A

符合附录 N 的电子附件:

欠压脱扣器:

$U_s$ : AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

分励脱扣器:

$U_s$ : AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

闭合线圈:

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅

## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2014010307696150

纸号: 290256

Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

注: 此附录与证书同时使用时有效。

主任: 陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>