

# 产品认证证书

## II型自愿认证

证书编号: CQC22107348293

发证日期: 2022年06月29日

有效期至: 2031年06月02日

**委托人名称** 浙江正泰电器股份有限公司  
**及注册地址** 浙江省乐清市北白象镇正泰工业园区正泰路1号

**制造商名称** 浙江正泰电器股份有限公司  
**及注册地址** 浙江省乐清市北白象镇正泰工业园区正泰路1号

**生产企业名称** 浙江亿德科技有限公司  
**及生产地址** 温州市龙湾区蒲州街道文绣路51号

**产品名称和系列、规格、型号** 智能集成电力电容补偿装置(低压成套无功功率补偿装置)  
产品型号: BAHB; 额定工作电压( $U_e$ ): 400V; 额定绝缘电压( $U_i$ ): 690V; 额定电流( $I_n$ ): 118A~6A; 额定限制短路电流( $I_{cc}$ ): 50kA; 额定总容量( $Q_c$ ): 100kvar~5kvar;  
外壳防护等级: IP30; 补偿相数: 混合补偿装置(单相、三相混合补偿); 投切电容器的元件类型: 复合开关; 户内型(户外型): 户内型; 频率: 50Hz; 最大补偿回路数: 4路;

**产品标准和技术要求** GB/T 15576-2020

**认证模式** 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站([www.cnca.gov.cn](http://www.cnca.gov.cn))查验证书信息



授权签字人

签发

陈志刚

谢肇煦



中国质量认证中心

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC22107348293

Valid from: Jun.29,2022

Valid until: Jun.02,2031

**NAME AND REGISTERED ADDRESS OF THE APPLICANT** Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND REGISTERED ADDRESS OF THE MANUFACTURER** Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND LOCATION OF THE FACTORY** ZHEJIANG YIDEK TECHNOLOGY CO.LTD.  
No.51,Wenxiu Road,Puzhou Street,Longwan Area, WenZhou City,Zhejiang

**PRODUCT NAME, MODEL AND SPECIFICATION** Intelligent integrated power capacitor compensation device  
产品型号: BAHB; 额定工作电压 (Ue): 400V; 额定绝缘电压 (Ui): 690V; 额定电流 (In): 118A~6A; 额定限制短路电流 (Icc): 50kA; 额定总容量 (Qc): 100kvar~5kvar; 外壳防护等级: IP30; 补偿相数: 混合补偿装置 (单相、三相混合补偿); 投切电容器的元件类型: 复合开关; 户内型 (户外型): 户内型; 频率: 50Hz; 最大补偿回路数: 4 路;

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS** GB/T 15576-2020

**TYPE OF CERTIFICATION SCHEMES** Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

杨志刚

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE