

IEC

IECEE

®

TM

Ref. Certif. No.

CN55966-M2/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Thermal Overload Relays

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang CHINT Electrics Co., Ltd.
No.2 Changjiang Road, CHINT Intelligent Electric Appliance
Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang
Province, P.R.China

Ratings and principal characteristics

Ui: 690V;Uimp: 8kV;Ue: AC690V;Ie:
23-32A,30-40A,37-50A,48-65A,55-70A,63-80A,
80-93A,80-100A;Trip class: 10A;Pole: 3P;IP20(Front
Side);Auxiliary contact:(body)1NO1NC;Ith: 5A;AC-15: Ue/Ie:
AC380V/400V/1.5A;DC-13: Ue/Ie: DC220V/0.2A

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

Additional information (if necessary may also be
reported on page 2)

NXR-100,NXRF-100;

A sample of the product was tested and found
to be in conformity withThe latest CB certificate No. is CN55966-M1/A1, dated
2023-08-22. The issuance of the M2 certificate is to change
the value of Uimp.As shown in the Test Report Ref. No. which
forms part of this CertificateIEC 60947-4-1:2018;IEC 60947-1:2007;IEC
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

00901-CB2021CQC-098294-M2/A1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.12,2023

Signature:

谢肇煦

Xie ZhaoXu



CB 0067813