

# 产品认证证书

## II型自愿认证

证书编号: CQC22107348292

发证日期: 2022年06月29日

有效期至: 2030年12月25日

委托人名称 浙江正泰电器股份有限公司  
及注册地址 浙江省乐清市北白象镇正泰工业园区正泰路1号

制造商名称 浙江正泰电器股份有限公司  
及注册地址 浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称 浙江亿德科技有限公司  
及生产地址 温州市龙湾区蒲州街道文绣路51号

产品名称和系列、规格、型号 智能抑制谐波无功补偿装置  
产品型号: BAFB-X; 额定工作电压 ( $U_e$ ): 400V; 额定绝缘电压 ( $U_i$ ): 690V; 额定电流 ( $I_n$ ): 42.0A ~ 2.1A; 额定限制短路电流 ( $I_{cc}$ ): 50kA; 额定总容量 ( $Q_c$ ): 40kvar ~ 2kvar; 外壳防护等级: IP30; 补偿相数: 单相补偿; 投切电容器的元件类型: 复合开关; 户内型 (户外型): 户内型; 频率: 50Hz; 最大补偿回路数: 3路; 具有抑制谐波功能

产品标准和技术要求 GB/T 15576-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 ([www.cnca.gov.cn](http://www.cnca.gov.cn)) 查验证书信息



授权签字人

签发

杨志刚

谢肇煦



中国质量认证中心

# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC22107348292

Valid from: Jun.29,2022

Valid until: Dec.25,2030

**NAME AND REGISTERED  
ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang  
Province, P.R.China

**NAME AND REGISTERED  
ADDRESS OF THE  
MANUFACTURER**

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang  
Province, P.R.China

**NAME AND LOCATION  
OF THE FACTORY**

ZHEJIANG YIDEK TECHNOLOGY CO.LTD.  
No.51,Wenxiu Road,Puzhou Street,Longwan Area, WenZhou City,Zhejiang

**PRODUCT NAME, MODEL  
AND SPECIFICATION**

Intelligent suppression harmonic reactive power compensation device  
产品型号:BAFB-X; 额定工作电压(Ue):400V; 额定绝缘电压(Ui):690V; 额定电流(InA):  
42.0A~2.1A; 额定限制短路电流(Icc):50kA; 额定总容量(Qc):40kvar~2kvar; 外壳防护等级:  
IP30; 补偿相数:单相补偿; 投切电容器的元件类型:复合开关; 户内型(户外型):户内型; 频率:  
50Hz; 最大补偿回路数:3路; 具有抑制谐波功能

**THE STANDARDS AND  
TECHNICAL REQUIREMENTS  
FOR THE PRODUCTS**

GB/T 15576-2020

**TYPE OF CERTIFICATION  
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

杨志刚

SIGNATURE

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE