



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

## CERTIFICATE OF CONFORMITY

Certificate No.: CE240303008960

**Product**

Moulded Case Circuit-breakers

**Applicant**

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**Type/Model**

NXM-1250S,H,NXMH-1250S,H,NXMP-1250S,H,NXMF-1250S,H,  
NXMS-1250S,H,NXMSH-1250S,H,NXMSP-1250S,H,NXMSF-1250S,H ;

**Technical data**

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2024CQC0303-014824, the submitted sample(s) of the above item complies with:

**EN 60947-2:2017/A1:2020;EN 60947-2:2017**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from: Jun.18,2024**

**Valid until: Jun.17,2027**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE



# CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

## CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE240303008960

NXM-1250S,H,NXMH-1250S,H,NXMP-1250S,H,NXMF-1250S,H,  
NXMS-1250S,H,NXMSH-1250S,H,NXMSP-1250S,H,NXMSF-1250S,H ;  
Uimp:12kV;  
Ui:1000V;  
Ue: Type S:AC220V/230V/240V,AC380V/400V/415V;  
Type H:AC220V/230V/240V,AC380V/400V/415V,660V/AC690V;  
In: Electronic: 1250A;  
In: Thermo-magnetic,electromagnetic:1000A,1250A;  
Over-current release:Thermo-magnetic,electromagnetic, electronic;  
Type S:AC220V/230V/240V:Ics=50kA,Icu=75kA;AC380V/400V/415V:Ics=36kA,Icu=50kA;  
Type H:AC220V/230V/240V:Ics=75kA,Icu=100kA;AC380V/400V/415V:Ics=50kA,Icu=70kA;  
660V/AC690V:Ics=20kA,Icu=30kA;  
Icw:19.2kA/1s (only electronic) ;  
50/60Hz;  
Selectivity category: A (thermo-magnetic, electromagnetic), B (electronic);  
Poles:3P,3P+N(3 protected poles with an uninterrupted neutral pole),  
4P(3 protected poles with a switched neutral pole) ,4P;  
Applicable for isolation(except 3P+N(3 protected poles with an uninterrupted neutral pole));  
Auxiliary contacts:AX-8/M8;1NO1NC,2NO2NC;  
Ith:2.5A;  
AC-15:Ue:AC380V/400V/415V,Ie:0.47A;  
DC-13:Ue:DC220V/240V;Ie:0.27A;  
Electronic Accessories complied with Annex N:  
Undervoltage release:UVT-M7:AC220V/230V/240V ,AC380V/400V/415V;  
Motor-operator:MD-M7:AC220V/230V/240V,AC380V/400V/415V ,DC110V,DC220V/250V



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE