



产品认证证书

证书编号: CQC2019010302209180

申请人名称及地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

制造商名称及地址

浙江正泰电器股份有限公司
浙江省乐清市北白象镇正泰工业园区正泰路1号

生产企业名称及地址

上海诺雅克电气有限公司(V012845)
上海市松江区思贤路3857号

产品名称和系列、规格、型号

隔离开关

NM8NSD-400;详见附件

产品标准和技术要求

GB/T14048.3-2017

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年06月01日 有效期至: 2024年07月22日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0290284



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2019010302209180

NAME AND ADDRESS OF THE APPLICANT

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province

NAME AND ADDRESS OF THE FACTORY

NOARK Electrics (Shanghai) Co., Ltd. (V012845)
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Switch Disconnecter
NM8NSD-400; See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection
This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019.

Valid from: Jun.01,2020

Valid until: Jul.22,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0290284



产品认证证书

附 录

第 1 页 共 3 页

证书编号: CQC2019010302209180

纸 号: 290284

NM8NSD-400

Uimp: 12kV;

Ui: 1000V;

Ith: 250A, 400A;

Ue: AC690V (3P, 4P), DC750V (3P 外形), DC1000V (4P 外形);

Ie: 250A, 400A;

Icw: 5kA/1s, 5kA/3s;

Icm(峰值): 8kA;

Icm: 5kA;

使用类别: AC22A, AC-23A, DC-22A, DC-23A, DC-PV2;

极数: 3P, 4P;

防护等级: IP20;

适用频率: 50/60Hz;

配用的辅助触头: AX21-M8, AL21-M8

1N01NC

Ith: 5A;

AC-15: Ue/Ie: AC110V/5A, AC240V/4A, AC415V/2A;

DC-13: Ue/Ie: DC110V/0.25A, DC220V/0.25A;

直流产品接线方式:

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



产品认证证书


附录

第 2 页 共 3 页


证书编号: CQC2019010302209180

纸号: 290284

DC750V




注: 1. 上、下进线皆可, 此处以下进线为例。




注: 1. 上、下进线皆可, 此处以下进线为例。
2. 确保安装方式不会发生二次接地故障。

DC1000V



注: 1. 上、下进线皆可, 此处以下进线为例。



注: 1. 上、下进线皆可, 此处以下进线为例。
2. 确保安装方式不会发生二次接地故障。

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附 录

第 3 页 共 3 页

证书编号: CQC2019010302209180

纸 号: 290284

型号解释:

NM8 N SD - 400

NM8: 根据NM8塑料外壳式断路器派生

N: 新系列

SD: 隔离开关代号

400: 壳架电流

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>