



# 中国国家强制性产品认证证书

证书编号：2024010304651719

**认证委托人名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**生产者名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**生产企业名称及地址**

上海诺雅克电气有限公司  
上海市松江区思贤路3857号

**产品名称和系列、型号、规格**

软起动器

NJRM5-□/D□SZ, NJRM5-□/D□, NJR5-□/D□, TR150-□/D□; 详见附页。

**产品标准和技术要求**

GB/T 14048.6-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》  
(CNCA-C03-02:2024)的要求, 特发此证。

发证日期: 2024年07月03日 有效期至: 2029年07月02日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,  
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司







# 中国国家强制性产品认证证书

证书编号：2024010304651719

证书附页：第 1 页 共 4 页

NJRM5-□/D□SZ , NJRM5-□/D□, NJR5-□/D□ , TR150-□/D□

Uimp:8kV;

Ui:详见下表;

Ith:见下表;

Pe:见下表;

Ue:见下表;

Ie:见下表;

使用类别:AC-53b;

极数: 3P;

防护等级: IP20

产品型号				Ue	Ui	Ie	Ith	Pe
NJRM5-440/D 2SZ	NJRM5-440/D 2	NJR5-440/ D2	TR150-440/ D2	AC220V	660V	404A	404A	110kW
NJRM5-500/D 2SZ	NJRM5-500/D 2	NJR5-500/ D2	TR150-500/ D2		660V	459A	459A	132kW
NJRM5-560/D 2SZ	NJRM5-560/D 2	NJR5-560/ D2	TR150-560/ D2		660V	514A	514A	160kW
NJRM5-630/D 2SZ	NJRM5-630/D 2	NJR5-630/ D2	TR150-630/ D2		660V	579A	579A	160kW
NJRM5-710/D 2SZ	NJRM5-710/D 2	NJR5-710/ D2	TR150-710/ D2		660V	634A	634A	200kW
NJRM5-440/D 3SZ	NJRM5-440/D 3	NJR5-440/ D3	TR150-440/ D3	AC380V	660V	404A	404A	220kW
NJRM5-500/D 3SZ	NJRM5-500/D 3	NJR5-500/ D3	TR150-500/ D3		660V	459A	459A	250kW
NJRM5-560/D 3SZ	NJRM5-560/D 3	NJR5-560/ D3	TR150-560/ D3		660V	514A	514A	280kW
NJRM5-630/D 3SZ	NJRM5-630/D 3	NJR5-630/ D3	TR150-630/ D3		660V	579A	579A	315kW
NJRM5-710/D 3SZ	NJRM5-710/D 3	NJR5-710/ D3	TR150-710/ D3		660V	634A	634A	355kW

本页为证书附页，应与证书主页同时使用。



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# 中国国家强制性产品认证证书

证书编号：2024010304651719

证书附页：第 2 页 共 4 页

产品型号				Ue	Ui	Ie	Ith	Pe
NJRM5-440/D 4SZ	NJRM5-440/D 4	NJR5-440/ D4	TR150-440/ D4	AC460V	1000V	404A	404A	250kW
NJRM5-500/D 4SZ	NJRM5-500/D 4	NJR5-500/ D4	TR150-500/ D4		1000V	459A	459A	280kW
NJRM5-560/D 4SZ	NJRM5-560/D 4	NJR5-560/ D4	TR150-560/ D4		1000V	514A	514A	315kW
NJRM5-630/D 4SZ	NJRM5-630/D 4	NJR5-630/ D4	TR150-630/ D4		1000V	579A	579A	355kW
NJRM5-710/D 4SZ	NJRM5-710/D 4	NJR5-710/ D4	TR150-710/ D4		1000V	634A	634A	400kW
NJRM5-440/D 5SZ	NJRM5-440/D 5	NJR5-440/ D5	TR150-440/ D5	AC575V	1000V	404A	404A	315kW
NJRM5-500/D 5SZ	NJRM5-500/D 5	NJR5-500/ D5	TR150-500/ D5		1000V	459A	459A	355kW
NJRM5-560/D 5SZ	NJRM5-560/D 5	NJR5-560/ D5	TR150-560/ D5		1000V	514A	514A	400kW
NJRM5-630/D 5SZ	NJRM5-630/D 5	NJR5-630/ D5	TR150-630/ D5		1000V	579A	579A	450kW
NJRM5-710/D 5SZ	NJRM5-710/D 5	NJR5-710/ D5	TR150-710/ D5		1000V	634A	634A	500kW
NJRM5-440/D 6SZ	NJRM5-440/D 6	NJR5-440/ D6	TR150-440/ D6	AC690V	1000V	404A	404A	400kW
NJRM5-500/D 6SZ	NJRM5-500/D 6	NJR5-500/ D6	TR150-500/ D6		1000V	459A	459A	400kW
NJRM5-560/D 6SZ	NJRM5-560/D 6	NJR5-560/ D6	TR150-560/ D6		1000V	514A	514A	500kW
NJRM5-630/D 6SZ	NJRM5-630/D 6	NJR5-630/ D6	TR150-630/ D6		1000V	579A	579A	560kW
NJRM5-710/D	NJRM5-710/D	NJR5-710/	TR150-710/		1000V	634A	634A	630kW

本页为证书附页，应与证书主页同时使用。



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# 中国国家强制性产品认证证书

证书编号: 2024010304651719

证书附页: 第 3 页 共 4 页

产品型号				Ue	Ui	Ie	Ith	Pe
6SZ	6	D6	D6					

型号的解释:



本页为证书附页, 应与证书主页同时使用。



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# 中国国家强制性产品认证证书

证书编号：2024010304651719

证书附页：第 4 页 共 4 页

T R 150 - □ / □ □

辅助代号 2: 主回路电压等级, 2 表示 AC220V 等级; 3 表示 AC380V 等级,  
4 表示 AC460V 等级; 5 表示 AC575V 等级; 6 表示 AC690V 等级。  
辅助代号 1: 工作方式, D 表示外置旁路式。  
规格代号: 软起动器额定机型电流 (单位: A)。  
设计序号: 150  
类别代号: 交流软起动器。  
企业特征代号: T

本页为证书附页，应与证书主页同时使用。



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010304651719

**NAME AND ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province,  
P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province,  
P.R.China

**NAME AND LOCATION OF THE FACTORY**

NOARK Electrics (Shanghai) Co., Ltd.

No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

**PRODUCT NAME,MODEL AND SPECIFICATION**

Soft Starter

NJRM5-□/D□SZ , NJRM5-□/D□, NJR5-□/D□ , TR150-□/D□ ; See the appendix.

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Jul.03,2024

**Valid until:** Jul.02,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to  
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



**SIGNATURE:**

谢肇煦



**中国质量认证中心**  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304651719

Appendix: Page 1 of 4

NJRM5-□/D□SZ , NJRM5-□/D□, NJR5-□/D□ , TR150-□/D□

Uimp:8kV;

Ui:See the following table;

Ith:See the following table;

Pe:See the following table;

Ue:See the following table;

Ie:See the following table;

Utilization Category: AC-53b;

Poles: 3P;

IP20

产品型号				Ue	Ui	Ie	Ith	Pe
NJRM5-440/D 2SZ	NJRM5-440/D 2	NJR5-440/ D2	TR150-440/ D2	AC220V	660V	404A	404A	110kW
NJRM5-500/D 2SZ	NJRM5-500/D 2	NJR5-500/ D2	TR150-500/ D2		660V	459A	459A	132kW
NJRM5-560/D 2SZ	NJRM5-560/D 2	NJR5-560/ D2	TR150-560/ D2		660V	514A	514A	160kW
NJRM5-630/D 2SZ	NJRM5-630/D 2	NJR5-630/ D2	TR150-630/ D2		660V	579A	579A	160kW
NJRM5-710/D 2SZ	NJRM5-710/D 2	NJR5-710/ D2	TR150-710/ D2		660V	634A	634A	200kW
NJRM5-440/D 3SZ	NJRM5-440/D 3	NJR5-440/ D3	TR150-440/ D3	AC380V	660V	404A	404A	220kW
NJRM5-500/D 3SZ	NJRM5-500/D 3	NJR5-500/ D3	TR150-500/ D3		660V	459A	459A	250kW
NJRM5-560/D 3SZ	NJRM5-560/D 3	NJR5-560/ D3	TR150-560/ D3		660V	514A	514A	280kW
NJRM5-630/D 3SZ	NJRM5-630/D 3	NJR5-630/ D3	TR150-630/ D3		660V	579A	579A	315kW
NJRM5-710/D 3SZ	NJRM5-710/D 3	NJR5-710/ D3	TR150-710/ D3		660V	634A	634A	355kW

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304651719

Appendix: Page 2 of 4

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

产品型号				Ue	Ui	Ie	Ith	Pe
NJRM5-440/D 4SZ	NJRM5-440/D 4	NJR5-440/ D4	TR150-440/ D4	AC460V	1000 V	404A	404A	250kW
NJRM5-500/D 4SZ	NJRM5-500/D 4	NJR5-500/ D4	TR150-500/ D4		1000 V	459A	459A	280kW
NJRM5-560/D 4SZ	NJRM5-560/D 4	NJR5-560/ D4	TR150-560/ D4		1000 V	514A	514A	315kW
NJRM5-630/D 4SZ	NJRM5-630/D 4	NJR5-630/ D4	TR150-630/ D4		1000 V	579A	579A	355kW
NJRM5-710/D 4SZ	NJRM5-710/D 4	NJR5-710/ D4	TR150-710/ D4		1000 V	634A	634A	400kW
NJRM5-440/D 5SZ	NJRM5-440/D 5	NJR5-440/ D5	TR150-440/ D5	AC575V	1000 V	404A	404A	315kW
NJRM5-500/D 5SZ	NJRM5-500/D 5	NJR5-500/ D5	TR150-500/ D5		1000 V	459A	459A	355kW
NJRM5-560/D 5SZ	NJRM5-560/D 5	NJR5-560/ D5	TR150-560/ D5		1000 V	514A	514A	400kW
NJRM5-630/D 5SZ	NJRM5-630/D 5	NJR5-630/ D5	TR150-630/ D5		1000 V	579A	579A	450kW
NJRM5-710/D 5SZ	NJRM5-710/D 5	NJR5-710/ D5	TR150-710/ D5		1000 V	634A	634A	500kW
NJRM5-440/D 6SZ	NJRM5-440/D 6	NJR5-440/ D6	TR150-440/ D6	AC690V	1000 V	404A	404A	400kW
NJRM5-500/D 6SZ	NJRM5-500/D 6	NJR5-500/ D6	TR150-500/ D6		1000 V	459A	459A	400kW
NJRM5-560/D 6SZ	NJRM5-560/D 6	NJR5-560/ D6	TR150-560/ D6		1000 V	514A	514A	500kW
NJRM5-630/D 6SZ	NJRM5-630/D 6	NJR5-630/ D6	TR150-630/ D6		1000 V	579A	579A	560kW
NJRM5-710/D 6SZ	NJRM5-710/D 6	NJR5-710/ D6	TR150-710/ D6		1000 V	634A	634A	630kW

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION


CERTIFICATE NO. : 2024010304651719

Appendix : Page 3 of 4

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

型号的解释:

**N IR M 5-□/ D □ SZ**



辅助代码 3: 产品定义类型, SZ 表示数智型。

辅助代号 2: 主回路电压等级, 2 表 AC220V 等级; 3 表示 AC380V 等级,  
4 表示 AC460V 等级; 5 表示 AC575V 等级; 6 表示 AC690V 等级。

辅助代号 1: 工作方式, D 表示外置旁路式。

规格代号: 软起动器额定机型电流


设计序号 5

专供代号: 行业 OEM

类别代号: 交流软起动器。

企业特征代号: N

**N IR M 5-□/ D □**



辅助代号 2: 主回路电压等级, 2 表 AC220V 等级; 3 表示 AC380V 等级,

4 表示 AC460V 等级; 5 表示 AC575V 等级; 6 表示 AC690V 等级。

辅助代号 1: 工作方式, D 表示外置旁路式。

规格代号: 软起动器额定机型电流


设计序号 5

专供代号: 行业 OEM

类别代号: 交流软起动器。

企业特征代号: N

**N IR 5-□/□□**



辅助代号 2: 主回路电压等级, 2 表 AC220V 等级; 3 表示 AC380V 等级,

4 表示 AC460V 等级; 5 表示 AC575V 等级; 6 表示 AC690V 等级。

辅助代号 1: 工作方式, D 表示外置旁路式。

规格代号: 软起动器额定机型电流 (单位: A)。

设计序号: 5

类别代号: 交流软起动器。

企业特征代号: N

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010304651719

Appendix : Page 4 of 4

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

T R 150 -□/□□

辅助代号 2: 主回路电压等级, 2 表示 AC220V 等级; 3 表示 AC380V 等级,  
4 表示 AC460V 等级; 5 表示 AC575V 等级; 6 表示 AC690V 等级。  
辅助代号 1: 工作方式, D 表示外置旁路式。  
规格代号: 软起动器额定机型电流 (单位: A)。  
设计序号: 150  
类别代号: 交流软起动器。  
企业特征代号: T

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.